



Anchorage School District
Purchasing Warehouse
4919 Van Buren Street
Anchorage, Alaska 99517
Phone (907) 742-8621

January 5, 2024

ADDENDUM NO. 2
This Addendum consists of: 2-Pages

TO: All ASD Plan Holders

SUBJECT: ITB 2024-809 Whaley Multi-Sensory De-Escalation Room Renovations

DUE DATE: Prior to 2:00 p.m., Local Time January 17, 2024

The following additions, corrections and changes are hereby made to the subject Invitation to Bid.

1. Reference Addendum No. 1 Enlarged Floor Plans Drawing Sheets A2.1, A2.2, A2.3, and A2.4 – **ADD** Keynote – NEW CHILL ROOMS NOTE NUMBER 6 to Chill Rooms 31, 37, 42, and 46 on all walls, **“Reference Detail 3/A9.03 SIM on all interior walls in Chill Rooms.”**
2. Reference Addendum No. 1 Drawing Sheet A2.4 – Enlarged Floor Plans, Detail 3 – **ADD** Keynote 4 “to all walls in Chill Room 46.”
3. Reference Addendum No. 1 Drawing Sheet A2.4 – Enlarged Floor Plans, Detail 3 – **ADD** the following new Keynote 6 to all walls in Storage 48, **“Prep and paint all existing walls.”**
4. Reference Addendum No. 1 Drawing Sheet A9.03 – Reflected Ceiling Plans - New, Detail 3 – There is a note that appears to have been written over. **REPLACE with, “(N) 6” HEAVY GA MTL STUD 16” O.C.”**

The following clarifications, questions and answers are provided for your use in responding to the subject Invitation to Bid:

- Q1: Drawing A2.4 detail 3 does not show keynote 4 applying to Chill Room 46. Please confirm is applicable as the demo plan show installing plywood in preparation for MDO assembly.
A1: Please reference the information provided in this Addendum.
- Q2: Please confirm what height the new MDO is to be installed to.
A2: Please reference the information provided in this Addendum.
- Q3: Please verify MDO assembly in RM 31, 37, 42 46, 75A, 75B. Sheet A1.01 detail 10 lists GYP in an MDO system but the keynotes on floor plans do not reference GYP
A3: Please reference the information provided in this Addendum.

All other terms and conditions remain the same.

Note to Bidders: This Addendum must be signed and returned with your bid or acknowledged where indicated in Section 00300. Failure to do so may cause your bid to be non-responsive.

Contractor Name: _____

Authorized Representative Signature: _____

Name and Title (please print): _____

END OF ADDENDUM